

ZELP

2xYDY 2x1,5mm<sup>2</sup>

kanal instalacyjny PCV dwudzielny KP90x60

2xYDY 2x1,5mm<sup>2</sup>

Architectural floor plan of a building showing a central corridor and surrounding rooms. The corridor is labeled "kanal instalacyjny PCV dwudzielnny KP90x60". It contains two "2xYDY 2x1,5mm2" cables on the left and a "3xYDY 2x1,5mm2" cable on the right. A "ZELP" (Zones of Earth Leakage Protection) is indicated on the right side of the corridor. The plan shows multiple rooms with doors and windows, and a central staircase area.

Instalację dzwonkową należy wykonać przewodem YDY 2x1,5mm<sup>2</sup> indywidualnie dla każdego mieszkania.

Zasilanie instalacji dzwonkowej z obwodu administracyjnego w ZELP.

W mieszkaniach należy zainstalować dzwonek bezzakłóconie na napięcie 8V~.

Zasilanie elektrozapachu napięciem 12V~ z obwodu adm. w ZELP. Otwieranie drzwi w korytarzu przyciskami dzwonkowymi zainstalowanymi przy drzwiach do mieszkań.

Przewody do instalacji dzwonkowej ułożyć w kanałach instalacyjnych KP 90x60.